



Test Report


Document OF : 2501
Page 1 of 4

Issued To Anees School Shivjot Enclave, Kharar Kharar	Sample Reg. No. :E01-2308040072 Sample Reg. Date :04-08-2023 Report Date :11-08-2023 Report No. :ICE-2308110403 NABL ULR No. :TC592623000009788F Customer Ref. No. :TRF Letter Dated :NS
	Test Report as per IS: BIS Specification IS:10500-2012 With Amendment No.(s): 01 to 04

PART A : PARTICULARS OF SAMPLE SUBMITTED

a)	Nature of Sample #	Drinking Water
b)	Sample Condition	Good
c)	Grade / Variety / Type / Class / Size etc.	NA
d)	Brand Name	NA
e)	Declared Values,if any	NA
f)	Code No.	
g)	Batch Number #	NA
h)	D.O.M #	NA
i)	Date of Expiry #	NA
j)	Sample Quantity #	2 Ltr
k)	Batch Size/Location #	NA
l)	Mode of Packing	Packed in bottles
m)	Date of Receipt	04-08-2023
n)	Date of Start	04-08-2023
o)	Date of Completion	11-08-2023
p)	Seal (Intact/Not Intact/Unsealed)	NA
q)	IO'S Signature (Signed/Unsigned)	Unsigned
r)	Any Other Information	NA


11-08-2023
Deepika Heera
[Authorized Signatory]


Vikrant
11-08-2023
Reviewer


11-08-2023
PremKumar
[Authorized Signatory]

Disclaimer :

- The report is only for the sample tested.
- Total liability of ITC Labs is limited to the invoiced amount.
- The test report shall not be reproduced except in full without the written approval of the laboratory.
- If samples not consumed during analysis, it will be stored and retain as per company policy.
- Samples not drawn by us unless otherwise stated.
- Test report in full or parts shall not be used for promotional or publicity purposes.
- Legal disputes are subjected to Panchkula Jurisdiction only.

Test Report

Document OF : 2501
Page 2 of 4

Issued To Anees School Shivjot Enclave, Kharar Kharar	Sample Reg. No. :E01-2308040072 Sample Reg. Date :04-08-2023 Report Date :11-08-2023 Report No. :ICE-2308110403 NABL ULR No. :TC592623000009788F Customer Ref. No. :TRF Letter Dated :NS
---	---

s)	Test Request Submitted By	Anees School-Kharar (Punjab)
t)	Manufactured By #	NA
u)	Supplied By #	NA


PART B : SUPPLIMENTARY INFORMATIONS


a.	Reference to sampling procedure, whenever applicable	: N/A
b.	Supporting documents for the measurement taken and results derived like graphs, tables, sketches and / or photographs as appropriate to test reports, if any	: N/A
c.	Deviation from the test methods as prescribed in relevant ISS/WORK Instruments, if any	: N/A

Description

Description	Clear colorless liquid
-------------	------------------------

S.No.	Parameters	Instrument	Method	Acceptable Limit	Permissible Limit	Result
Discipline : Chemical						
Group : Water						
1.	Organoleptic & Physical Parameter					
a.	Colour (True Colour)	Visual	IS 3025 (Part 4) : 2021	5 Max.	15 Max.	2
b.	Taste	Organoleptic	IS:3025(Part 8):1984(RA:2017)	Agreeable	Agreeable	Agreeable
c.	Odour	Organoleptic	IS: 3025 (P-5)-2018	Agreeable	Agreeable	Agreeable
d.	Turbidity (NTU)	Turbidity Meter	IS:3025(Part 10):1984(RA:2017)	1 Max.	5 Max.	<0.5


11-08-2023
Deepika Heera
[Authorized Signatory]


Vikrant
11-08-2023
Reviewer


11-08-2023
PremKumar
[Authorized Signatory]

Disclaimer :

- The report is only for the sample tested.
- Total liability of ITC Labs is limited to the invoiced amount.
- The test report shall not be reproduced except in full without the written approval of the laboratory.
- If samples not consumed during analysis, it will be stored and retain as per company policy.
- Samples not drawn by us unless otherwise stated.
- Test report in full or parts shall not be used for promotional or publicity purposes.
- Legal disputes are subjected to Panchkula Jurisdiction only.


Test Report

Document OF : 2501
Page 3 of 4


Issued To Anees School Shivjot Enclave, Kharar Kharar			Sample Reg. No. :E01-2308040072 Sample Reg. Date :04-08-2023 Report Date :11-08-2023 Report No. :ICE-2308110403 NABL ULR No. :TC592623000009788F Customer Ref. No. :TRF Letter Dated :NS			
e.	pH Value	pH Meter	IS: 3025 (Part-11): 2022	6.5-8.5	No relaxation	8.40
f.	Total Dissolved Solids,(mg/L)	Gravimetric	IS: 3025 (P-16)-1984 (RA 2017)	500 Max.	2000 Max.	190
2. Parameters Concerning Undesirable Substances in excess amount						
a.	Chloride(as Cl)(mg/L)	Titration	IS: 3025 (P-32)-1988 (RA2019)	250 Max.	1000 Max.	16
b.	Fluoride as F(mg/L)	Visual	IS: 3025 (P-60)-2008 (RA 2019)	1.0 Max.	1.5 Max.	BLQ(LOQ:0.1)
c.	Free Residual Chlorine, (mg/L)	Titration	IS: 3025 (P-26): 2021	0.2 Min.	1.0 Max.	Not Applicable
d.	Iron (as Fe)(mg/L)	UV-Spectrophotometer	IS: 3025 (P-53)-2003 (RA 2019)	1.0 Max.	No relaxation	BLQ(LOQ:0.08)
e.	Total Hardness(as CaCO ₃),(mg/L)	Titration	IS: 3025 (Part 21)-2009 (RA 2019)	200 Max.	600 Max.	58
Discipline : Biological						
Group : Water						
1. Microbiological Tests						
a.	E. Coli	Microbiological	IS 15185: 2016	Shall not be detectable in any 100 ml sample	No Relaxation	Absent/100ml
b.	Total Coliform	Microbiological	IS 15185: 2016	Shall not be detectable in any 100 ml sample	No Relaxation	Absent/100ml

represents Customer Defined Fields


NOTE : NA- Not Applicable, BLQ- Below limit of Quantification, LOQ- Limit of Quantification. Sample Submitted by Customer



11-08-2023
Deepika Heera
[Authorized Signatory]



Vikrant
11-08-2023
Reviewer



11-08-2023
PremKumar
[Authorized Signatory]

Disclaimer :

- The report is only for the sample tested.
- Total liability of ITC Labs is limited to the invoiced amount.
- The test report shall not be reproduced except in full without the written approval of the laboratory.
- If samples not consumed during analysis, it will be stored and retain as per company policy.
- Samples not drawn by us unless otherwise stated.
- Test report in full or parts shall not be used for promotional or publicity purposes.
- Legal disputes are subjected to Panchkula Jurisdiction only.

Test Report

Document OF : 2501
Page 4 of 4


Issued To Anees School Shivjot Enclave, Kharar Kharar	Sample Reg. No. :E01-2308040072 Sample Reg. Date :04-08-2023 Report Date :11-08-2023 Report No. :ICE-2308110403 NABL ULR No. :TC592623000009788F Customer Ref. No. :TRF Letter Dated :NS
---	---

REMARKS :The above referred sample of Drinking Water conforms to BIS Specification IS:10500-2012 with upto date amdots with respect to the above tests.


*****End Of Report*****



11-08-2023
Deepika Heera
[Authorized Signatory]



Vikrant
11-08-2023
Reviewer



11-08-2023
PremKumar
[Authorized Signatory]

Disclaimer :

- The report is only for the sample tested.
- Total liability of ITC Labs is limited to the invoiced amount.
- The test report shall not be reproduced except in full without the written approval of the laboratory.
- If samples not consumed during analysis, it will be stored and retain as per company policy.
- Samples not drawn by us unless otherwise stated.
- Test report in full or parts shall not be used for promotional or publicity purposes.
- Legal disputes are subjected to Panchkula Jurisdiction only.

OFFICE OF THE MUNICIPAL COUNCIL KHARAR

(Distt. S. A. S. Nagar)

ਦਫ਼ਤਰ ਨਗਰ ਕੌਂਸਲ, ਖਰੜ (ਜ਼ਿਲ੍ਹਾ ਐਸ.ਏ.ਐਸ. ਨਗਰ)

ਨੰ- 1943

ਮਿਤੀ - 18/8/2023

Sanitary Condition Certificate

Anee's School, Shivjot Enclave, Kharar, ਦੀ ਦਰਖਾਸਤ ਮਿਤੀ 16-08-2023 ਦੇ ਸਬੰਧ ਵਿੱਚ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਉਕਤ ਸਕੂਲ ਦਾ ਸੈਨਟਰੀ ਇੰਸਪੈਕਟਰ, ਨਗਰ ਕੌਂਸਲ ਖਰੜ ਵੱਲੋਂ ਮੌਕਾ ਦੇਖਿਆ ਗਿਆ ਅਤੇ ਮੌਕੇ ਤੇ ਪਾਇਆ ਗਿਆ ਕਿ ਸਕੂਲ ਦਾ Toilet ਬਲਾਕ ਸਾਫ਼ ਸੁਥਰਾ ਹੈ, ਇਸ ਨੂੰ ਸਕੂਲ ਵੱਲੋਂ ਬਣਾਏ ਟੈਂਕ ਦੇ ਨਾਲ ਜੋੜਿਆ ਗਿਆ ਹੈ ਅਤੇ ਭਵਿੱਖ ਵਿੱਚ ਇਸ ਦੀ ਸਾਫ਼ ਸਫਾਈ ਅਤੇ ਮੈਨਟੇਨ ਕਰਨ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ।


ਕਾਰਜ ਸਾਧਕ ਅਫ਼ਸਰ

ਨਗਰ ਕੌਂਸਲ ਖਰੜ
